



# 中国国家强制性产品认证证书



证书编号: 2020322304001095

认证委托人名称: 博太科防爆设备(上海)有限公司  
 认证委托人地址: 上海市闵行区浦江高科技园区新骏环路188号7号楼101、401  
 生产者名称: BARTEC GmbH  
 生产者地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany  
 生产企业名称: BARTEC GmbH  
 生产企业地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany  
 产品名称: 控制、开关和指示模块  
 系列、规格、型号: 07-33 系列  
 标准: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、  
 GB/T 3836.4-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年04月06日

有效期至: 2025年09月06日

首次发证日期: 2020年09月07日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准:



## 上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322304001095**

**APPLICANT:** BARTEC Explosion Proof Appliances (Shanghai) Co. Ltd  
**ADDRESS:** Building 7, 101, 401, No. 188, Xinjun Ring Rd., Shanghai Pujiang Hi-Tech Park(Pu Dong Area), Minhang District, Shanghai China

**MANUFACTURER:** BARTEC GmbH  
**ADDRESS:** Max-Eyth-Str. 16 97980 Bad Mergentheim Germany  
**FACTORY:** BARTEC GmbH  
**ADDRESS:** Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

**PRODUCT:** Control, Switching and Display Module  
**SERIES,SPECIFICATION,MODEL:** 07-33 series  
**STANDARDS:** GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.4-2021、GB/T 3836.31-2021

**Type of Certification: Type test + Initial inspection + Surveillance inspection**

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

**Valid from:** April 6, 2023

**Valid until:** September 6, 2025

**Date of original certification:** September 7, 2020

**The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

**S 0007219**





# 中国国家强制性产品认证证书



证书编号：2020322304001095

## 附 件

相关报告编号： 2023S17402-010930、2020S17402-001461

**使用条件：**

1. 特殊（限制）使用条件：
  - 1) 产品的安装方式必须保证产品外壳可以避免机械冲击和静电电荷集聚的风险。
  - 2) 产品使用环境温度范围为：-55℃~+60℃。
2. 外壳防护等级为 IP66。

批 准：



### 上海仪器仪表自控系统检验测试所有限公司